

**Easytop circulation regulation valve S/E,
static regulation valve with G-thread**

Instructions for Use



for hydraulic line calibration in drinking water installations

Model
2282.1

Year built:
from 11/2011

en_INT

viega

Table of contents

1	About these instructions for use	4
1.1	Target groups	4
1.2	Labelling of notes	4
1.3	About this translated version	5
2	Product information	6
2.1	Standards and regulations	6
2.2	Intended use	8
2.2.1	Areas of use	8
2.2.2	Media	8
2.3	Product description	9
2.3.1	Overview	9
2.3.2	Threaded connection	9
2.3.3	Markings on components	10
2.3.4	Compatible components	10
2.3.5	Operating mode	10
2.3.6	Technical data	10
2.4	Information for use	13
2.4.1	Corrosion	13
2.5	Optional accessories	14
3	Handling	15
3.1	Assembly information	15
3.1.1	Mounting instructions	15
3.1.2	Required tools	15
3.2	Assembly	16
3.2.1	Installation position and settings	16
3.2.2	Set valve	17
3.2.3	Leakage test	19
3.3	Maintenance	19
3.4	Disposal	19

1 About these instructions for use

Trade mark rights exist for this document; for further information, go to viega.com/legal.

1.1 Target groups

The information in this manual is directed at heating and sanitary professionals and trained personnel.

Individuals without the abovementioned training or qualification are not permitted to mount, install and, if required, maintain this product. This restriction does not extend to possible operating instructions.

The installation of Viega products must take place in accordance with the general rules of engineering and the Viega instructions for use.

1.2 Labelling of notes

Warning and advisory texts are set aside from the remainder of the text and are labelled with the relevant pictographs.



DANGER!

This symbol warns of possible life-threatening injury.



WARNING!

This symbol warns of possible serious injury.



CAUTION!

This symbol warns of possible injury.



NOTICE!

This symbol warns of possible damage to property.



This symbol gives additional information and hints.

1.3 About this translated version

This instruction for use contains important information about the choice of product or system, assembly and commissioning as well as intended use and, if required, maintenance measures. The information about the products, their properties and application technology are based on the current standards in Europe (e. g. EN) and/or in Germany (e. g. DIN/DVGW).

Some passages in the text may refer to technical codes in Europe/Germany. These should serve as recommendations in the absence of corresponding national regulations. The relevant national laws, standards, regulations, directives and other technical provisions take priority over the German/European directives specified in this manual: The information herein is not binding for other countries and regions; as said above, they should be understood as a recommendation.

2 Product information

2.1 Standards and regulations

The following standards and regulations apply to Germany / Europe and are provided as a support feature.

Regulations from section: Fields of application

Scope / Notice	Regulations applicable in Germany
Planning, execution, operation and maintenance of potable water installations	DIN EN 806, part 1
Planning, execution, operation and maintenance of potable water installations	DIN EN 806, part 2
Planning, execution, operation and maintenance of potable water installations	DIN EN 806, part 3
Planning, execution, operation and maintenance of potable water installations	DIN EN 806, part 4
Planning, execution, operation and maintenance of potable water installations	DIN EN 806, part 5
Planning, execution, operation and maintenance of potable water installations	DIN EN 1717
Planning, execution, operation and maintenance of potable water installations	DIN 1988
Planning, execution, operation and maintenance of potable water installations	VDI/DVGW 6023
Planning, execution, operation and maintenance of potable water installations	Trinkwasserverordnung (TrinkwV)
Planning, execution, operation and maintenance of potable water installations	DVGW-Arbeitsblatt W 553

Regulations from section: Media

Scope / Notice	Regulations applicable in Germany
Suitability for drinking water	Trinkwasserverordnung (TrinkwV)

Regulations from section: Product description

Scope / Notice	Regulations applicable in Germany
Suitability for drinking water installations	Trinkwasserverordnung (TrinkwV)
Suitability for drinking water installations	DIN 50930-6
Requirements in plastic components in drinking water installations	DVGW-Arbeitsblatt W270

Regulations from section: Compatible components

Scope / Notice	Regulations applicable in Germany
G-external threads	DIN EN ISO 228

Regulations from section: Corrosion

Scope / Notice	Regulations applicable in Germany
External corrosion protection	DIN EN 806-2
External corrosion protection	DIN 1988-200
External corrosion protection	DKI-Informationsdruck i. 160

Regulations from section: Installation position and settings

Scope / Notice	Regulations applicable in Germany
Dimensioning of circulation systems	DVGW-Arbeitsblatt W 553

Regulations from section: Leakage test

Scope / Notice	Regulations applicable in Germany
Leakage test for potable water installations	DIN EN 806, part 4
Leakage test for potable water installations	ZVSHK-Merkblatt „Dichtheitsprüfungen von Trinkwasserinstallationen mit Druckluft, Inertgas oder Wasser“

Regulations from section: Maintenance

Scope / Notice	Regulations applicable in Germany
Operation and maintenance of potable water installations	DIN EN 806-5

2.2 Intended use



Coordinate the use of the model for areas of use and media other than those described with the Viega Service Center.

The functionality of the valve is only ensured by professional design and assembly of the complete system.

2.2.1 Areas of use

Use is possible in the following areas among others:

- Hot water circulation pipelines
- Internally and parallel laid circulation pipes

The general rules of engineering and the applicable regulations must be observed for planning, execution, operation and maintenance potable water installations, see ↪ „Regulations from section: Fields of application“ on page 6.

2.2.2 Media

The model is also suitable for the following media, amongst others:

- Drinking water without limitations acc. to the applicable directives, see ↪ „Regulations from section: Media“ on page 7
- maximum chloride concentration 250 mg/l pursuant to applicable regulations, see ↪ „Regulations from section: Media“ on page 7

2.3 Product description

According to the applicable regulations, Easytop system fittings can be used for all types of potable water and are DVGW certified, see  „Regulations from section: Product description“ on page 7. Their plastic components comply with the KTW recommendation and the requirements pursuant to the applicable regulations.

2.3.1 Overview

The model is equipped as follows:

- valve casing made of gunmetal/silicon bronze
- valve top made of gunmetal/silicon bronze
- dual-sided G external thread
- drain plugs for drainage valve G ¼
- setting scale
- handwheel with exchangeable coloured plastic cap as media labelling
- key surface on the casing

The static circulation regulation valve can be used to equalise and shut-off pipe sections. The set flowthrough volume can be fixed mechanically. The set value is not altered by opening and closing the valve.

The model is available in the following dimensions:

DN	15	20	25
G	¾	1	1¼

2.3.2 Threaded connection

Only flat sealing connection screw fittings may be used for the threaded connection.



Sealing of the G-threads takes place by pressing the sealing surfaces together. For this reason, no additional sealants (hemp, sealing paste / thread etc.) may be used.

2.3.3 Markings on components

The model is marked as follows:

- flow direction indicator
- dimension
- DVGW writing
- setting scale

2.3.4 Compatible components

The model is equipped with G-external threads according to the applicable regulations and compatible with the Profipress, Sanpress, and Sanpress Inox system, see ↗ „Regulations from section: Compatible components“ on page 7.

2.3.5 Operating mode

The static Easytop circulation regulation valve is used in circulation pipes and allows hydraulic line calibration. The calibration takes place via a reproducible presetting.

2.3.6 Technical data

Observe the following operating conditions for the installation of the model:

Operating temperature [T_{max}]	90 °C
Operating pressure [P_{max}]	1.0 MPa (10 bar)
Setting range	0 - 6.9

Target values

The required set values can be obtained from the diagrams below. The intermediate values can be set steplessly.




Fig. 1: Diagram set values DN15




Fig. 2: Diagram set values DN20




Fig. 3: Diagram set values DN25

2.4 Information for use

2.4.1 Corrosion

Overground pipelines and fittings in rooms do not normally require external corrosion protection.

There are exceptions in the following cases:

- Contact with aggressive building materials such as nitrite or materials containing ammonium
- in aggressive surroundings

If external corrosion protection is required, observe the pertinent guidelines, see [☞ „Regulations from section: Corrosion“ on page 7.](#)



Easytop fittings made of gunmetal/silicon bronze are suitable for all types of potable water.

The chloride concentration in the medium must not exceed a maximum value of 250 mg/l.

This chloride is not a disinfectant, but in fact pertains to the content in sea and table salt (sodium chloride).

2.5 Optional accessories

The following optional accessories are available:

- Drainage valve
- Thermometer
- Insulating shell



Fig. 4: Model 2234.6 Easytop drainage valve



Fig. 5: Model 1026.6 Easytop thermometer



Fig. 6: Model 2210.35, insulating shell

EPS insulating shells are available for the static circulation regulation valve. The two-piece insulating shells are self-supporting and are mounted without tools and holding grips. They close seamlessly on the front surface of the pipeline insulation.

3 Handling

3.1 Assembly information

3.1.1 Mounting instructions

Checking system components



Do not remove the model from the packaging until immediately before use.

System components may, in some cases, become damaged through transportation and storage.

- Check all parts.
- Replace damaged components.
- Do not repair damaged components.
- Contaminated components may not be installed.

During assembly

Observe the following when mounting:

- use suitable tools
- flow direction indicator
- When tightening the connection screw fitting, counter by holding the key surface of the valve.
- A piece of straight pipe of at least 3xd should be installed upstream from the fitting.



Choose the place of installation so that the fitting is easily accessible, simple to operate and the insulating shell can be well mounted.

Laying and fixing pipes

For information, refer to the instructions for use of the Profipress, Sanpress and Sanpress Inox systems.

Length expansion

For information, refer to the instructions for use of the Profipress, Sanpress and Sanpress Inox systems.

3.1.2 Required tools

Target values

An Allen key (size 2) is required to pre-set the target values.

3.2 Assembly

3.2.1 Installation position and settings

Installation position

Installation is possible in the riser pipe.

If there are multiple riser pipes on the storey during the installation of the thermostatic circulation regulation valve, then every riser pipe must have a circulation regulation valve mounted, see Fig. 7.



NOTICE!

According to the applicable directives, circulation regulation valves must be installed between the outlet of the hot water tank and the circulation inlet, see „Regulations from section: Installation position and settings“ on page 7.




Fig. 7: Static CRV in the riser pipe

Settings


- Set the calculated flow values (see „Target values“ on page 10) before commissioning.

3.2.2 Set valve


Setting is shown using model 2282 as an example.

Before commissioning:


- Set the valve to the calculated flow value.




The set flow quantity can be fixed mechanically. We recommend the following steps to prevent the set value being adjusted by the opening and closing of the valve:




- Remove the cover.




- Mark the position of the handwheel on the spindles.




► Remove the handwheel.




► Loosen the screw with the Allen key (SS 2).



► Screw the adjusting screw (SS 11) into the valve as far as it will go; at the same time, hold the spindle (SS 6) tight.



► Tighten the screw again with the Allen key (SS 2).



- Position the handwheel as marked and mount the lid.
 - ⇒ The circulation regulation valve is now ready for use.

3.2.3 Leakage test

The installer must perform a leakage test before commissioning.

Carry out this test on a system that is finished but not yet covered.

Comply with the general rules of engineering and the applicable directives, see ↗ „Regulations from section: Leakage test“ on page 8.

Document the result.

3.3 Maintenance



NOTICE!

Inform your customer or the operator of the drinking water installation that the system has to be maintained on a regular basis.

Observe the applicable regulations for the operation and maintenance of drinking water installations, see ↗ „Regulations from section: Maintenance“ on page 8.

3.4 Disposal

Separate the product and packaging materials (e. g. paper, metal, plastic or non-ferrous metals) and dispose of in accordance with valid national legal requirements.