

Seal set

Instructions for Use



for pipe interrupter insert

Model
6161.84

en_INT

Year built:
from 01/2000



Table of contents

1	About these instructions for use	4
1.1	Target groups	4
1.2	Labelling of notes	4
1.3	About this translated version	5
2	Product information	6
2.1	Area of application	6
2.2	Product description	6
3	Handling	7
3.1	Assembly	7
3.1.1	Mounting O-rings	7
3.2	Disposal	8

1 About these instructions for use

1.1 Target groups

The information in this instruction manual is directed at the following groups of people:

- Heating and sanitary professionals and trained personnel

It is not permitted for individuals without the abovementioned training or qualification to mount, install and, if required, service this product. This restriction does not extend to possible operating instructions.

The installation of Viega products must take place in accordance with the general rules of engineering and the Viega instructions for use.

1.2 Labelling of notes

Warning and advisory texts are set aside from the remainder of the text and are labelled with the relevant pictographs.



DANGER!

This symbol warns against possible life-threatening injury.



WARNING!

This symbol warns against possible serious injury.



CAUTION!

This symbol warns against possible injury.



NOTICE!

This symbol warns against possible damage to property.



Notes give you additional helpful tips.

1.3 About this translated version

This instruction for use contains important information about the choice of product or system, assembly and commissioning as well as intended use and, if required, maintenance measures. The information about the products, their properties and application technology are based on the current standards in Europe (e. g. EN) and/or in Germany (e. g. DIN/DVGW).

Some passages in the text may refer to technical codes in Europe/Germany. These should serve as recommendations in the absence of corresponding national regulations. The pertinent national laws, standards, regulations and guidelines, as well as other technical guidelines, have priority over German/European guidelines in this manual: The information is not binding for other countries and territories and should, as mentioned, be considered as support.

2 Product information

2.1 Area of application

The O-rings are suitable for concealed pipe interrupter inserts, model 6161.81.

Seals on the pipe interrupter insert can be replaced in the case of extreme contamination, limescale or damage.

2.2 Product description

The seal set consists of two identical O-rings, which are inserted into the top and bottom rim of the pipe interrupter insert.


3 Handling

3.1 Assembly


3.1.1 Mounting O-rings

Proceed as follows to replace the seal of the insert:

➤ Remove rosette.





➤ Pull the insert out of the casing using multigrip pliers.




➤ Remove old O-ring.

➤ Insert new O-ring.





- Using multigrip pliers, insert the insert into the casing of the pipe interrupter vertically from the front.



- Insert the rosette into the shaft top.

3.2 Disposal

Separate the product and packaging materials (e. g. paper, metal, plastic or non-ferrous metals) and dispose of in accordance with valid national legal requirements.